

CERTIFICATE
OF CONFORMITY

N. 033/15

ISSUED TO THE COMPANY

F.B.M. - Fornaci Briziarelli Marsciano S.p.A.

Via XXIV Maggio - 06055 Marsciano (PG)

FOR THE FACTORY

Località Fornaci - 06055 Marsciano (PG)

FOR THE PRODUCT

Coppo Piccolo

This Certificate of Conformity has a yearly validity from the date of issue.

Type tests were made on samples selected in the factory by qualified personnel of laboratory CertiMaC

Type test results are available in test report n° 010118 - R - 4292 annexed to this Certificate of Conformity

CERTIMAC DECLARES THAT THE ABOVE MENTIONED PRODUCT HAS SUCCESSFULLY OVERCOME THE LABORATORY TESTS IN ACCORDANCE WITH THE TYPE TESTS OF THE STANDARDS

UNI EN 1304, UNI EN 1024, UNI EN 538, UNI EN 539-1, UNI EN 539-2

IMPERMEABILITY: Method 1
Category of Impermeability 1

FROST RESISTANCE: European single test method, Level 1 (150 cycles)

First Issue 04/26/2007

Eng. Luca Laghi

Current Issue 04/02/2015

